GPU inspection checklist

Date _____ **Time** _____

Station or ramp _____ **Operator name** _____

Unit number _____ **Hours** _____

Cables and connectors	Pass	Fail	N/A
Cable jacket has no cuts, crushing, burns or exposed wire	☐	☐	☐
Connector pins, plug and housing are clean and undamaged	☐	☐	☐
Strain relief at both ends is intact	☐	☐	☐
Cable storage or reel works and holds the cable off the ground	☐	☐	☐
Grounding connection and cable are in good condition	☐	☐	☐

Unit	Pass	Fail	N/A
Housing, doors and guards are in place and secure	☐	☐	☐
Controls, switches and indicators work	☐	☐	☐
Emergency stop works	☐	☐	☐
Engine: oil, coolant and fuel levels, no leaks, or battery is secure and charged	☐	☐	☐
No fluid leaks under the unit	☐	☐	☐
Exhaust and cooling areas are clear	☐	☐	☐

Mobility and safety	Pass	Fail	N/A
Tires and wheels are in good condition	☐	☐	☐
Brakes or chocks hold the unit	☐	☐	☐
Tow bar or hitch is secure	☐	☐	☐
Fire extinguisher is present and charged	☐	☐	☐
Warning labels and data plate are on and readable	☐	☐	☐

Defects found and action taken

_____

_____

_____

Taken out of service? ☐ Yes ☐ No **Reported to** _____

Inspector signature _____ **Date** _____

Supervisor review _____ **Date** _____